

PUBLIC WORKS & UTILITIES ENGINEERING & DESIGN STANDARDS

PROPOSED UTILITY	HORIZONTAL & VERTICAL SEPARATION REQUIREMENTS								ACCEPTABLE VARIANCES
	POTABLE WATER		RECLAIMED WATER*		SANITARY SEWER (GRAVITY & F.M.)		STORM SEWER		
	HORIZ.	VERT.	HORIZ.	VERT.	HORIZ.	VERT.	HORIZ.	VERT.	
POTABLE WATER	---	---	3' O/O	12"	6'	6" 12" FM	3'	6"	SEE GENERAL NOTES: NO. 4
RECLAIMED* WATER	3' O/O	12"	---	---	3' O/O	12"	3'	6"	
SANITARY SEWER	6'	6" 12" FM	3' O/O	12"	---	---	3'	6"	

GENERAL NOTES:

- 1) THE TABLE REPRESENTS THE MINIMUM SEPARATION REQUIREMENTS AS DESCRIBED IN F.D.E.P. RULES OF THE FLORIDA ADMINISTRATION CODE (F.A.C.). THESE SEPARATION REQUIREMENTS SHALL APPLY BETWEEN NEWLY PROPOSED UTILITY LINES AND EXISTING OR PROPOSED UTILITY LINES.
- * 2) FOR THE PURPOSE OF THIS TABLE, RECLAIMED WATER SHALL MEAN UNRESTRICTED PUBLIC ACCESS REUSE WATER AS DEFINED BY F.A.C. 62-610. OTHER TYPES OF RECLAIMED WATER ARE SEWAGE AND SEPARATIONS LISTED FOR SANITARY SEWER SHALL APPLY.
- 3) ALL SEPARATION DISTANCES ARE FROM OUTSIDE OF PIPE TO OUTSIDE OF PIPE UNLESS OTHERWISE SPECIFIED. CRITERION PRODUCING GREATER CLEARANCE SHALL BE USED.
 - C/C -DENOTES CENTER OF PIPE TO CENTER OF PIPE.
 - O/O -DENOTES OUTSIDE OF PIPE TO OUTSIDE OF PIPE.
- 4) REQUIRES PRIOR APPROVAL FROM FDEP.



CITY OF ALTAMONTE SPRINGS
950 CALABRIA DRIVE
ALTAMONTE SPRINGS, FLORIDA 32714

UTILITY PIPE MIN. SEPARATION REQUIREMENTS TABLE

GU006-4

ISSUED 2017

REVISED 03/01/2017 BY DJB