



PUBLIC WORKS & UTILITIES ENGINEERING & DESIGN STANDARDS



FIRE LANE MARKINGS

1. SIGNS SHALL BE HIGH INTENSITY RETROREFLECTIVE, TWELVE (12) INCHES WIDE BY EIGHTEEN (18) INCHES IN HEIGHT, WHITE WITH THREE-INCH HIGH RED LETTERS NOT LESS THAN ONE-HALF INCH WIDE TO READ "NO PARKING FIRE LANE".
2. SIGNS SHALL BE DOUBLE FACED, FACE THE DIRECTION OF TRAFFIC FLOW AND SPACED NOT GREATER THAN SIXTY (60) FEET APART. NO PART OF THE FIRE LANE SHALL BE FURTHER THEN 30 FEET FROM A SIGN.
3. SIGNS SHALL BE MOUNTED ON METAL POSTS, NOT LESS THAN TWO (2) INCHES IN SIZE.
4. THE MINIMUM HEIGHT, MEASURED VERTICALLY FROM THE BOTTOM OF THE SIGN TO THE TOP OF THE CURB, OR IN THE ABSENCE OF CURB, MEASURED VERTICALLY FROM THE BOTTOM OF THE SIGN TO THE ELEVATION OF THE NEAR EDGE OF THE TRAVELED WAY SHALL BE 7 FEET.
5. WHERE A CURB IS PROVIDED, FOUR INCHES (4") OF CURB TOP AND FACE TO BE TRAFFIC YELLOW (FDOT TRAFFIC RATED PAVEMENT PAINT). STRIPES SHALL BE FOUR INCHES (4") WIDE EXTENDING OUTWARD TO A WIDTH OF FOUR (4) FEET FROM CURB WITH THREE (3) FEET BETWEEN EACH STRIPE. STRIPING TO BE TWO (2) COATS OF YELLOW, FDOT TRAFFIC-RATED PAVEMENT PAINT.
6. LETTERS NOT LESS THAN FOUR (4) INCHES IN HEIGHT AND NOT LESS THAN TWO (2) INCHES IN WIDTH WITHIN THE STRIPING (BETWEEN THE POSTED SIGNS) TO READ "NO PARKING FIRE LANE". LETTERING TO BE TRAFFIC YELLOW FDOT TRAFFIC RATED PAVEMENT PAINT.
7. SIGNS AND PAINTING ARE TO BE MAINTAINED BY THE PROPERTY OWNER.



LOADING ZONE MARKINGS

1. STRIPES SHALL BE FOUR INCHES (4") WIDE EXTENDING OUTWARD WITH FOUR (4) FEET BETWEEN EACH STRIPE. STRIPING TO BE TWO (2) COATS OF YELLOW, FDOT TRAFFIC-RATED PAVEMENT PAINT.
2. LETTERS NOT LESS THAN FOUR (4) INCHES IN HEIGHT AND NOT LESS THAN TWO (2) INCHES IN WIDTH TO READ "NO PARKING LOADING ZONE". LETTERING TO BE TRAFFIC YELLOW FDOT TRAFFIC RATED PAVEMENT PAINT.
3. LOADING ZONE SIZING SHALL BE PER CITY OF ALTAMONTE SPRINGS LAND DEVELOPMENT CODE 3.41.5.



CITY OF ALTAMONTE SPRINGS
950 CALABRIA DRIVE
ALTAMONTE SPRINGS, FLORIDA 32714

TYPICAL FIRE LANE AND LOADING ZONE REQUIREMENTS

MI002-1

ISSUED 2017

REVISED 03/08/2017 BY DJB